



Department of Commerce

Division of State Fire Marshal
 John R. Kasich, Governor
 Jacqueline T. Williams, Director

BUSTR - Acronyms Used to Describe Underground Storage Tank (UST) Systems

(1) Status CIU - Currently in Use REM - Removed CIP - Closed in Place CIS - Change in Service Other - See Comments (Fee Eligible) OOS1 - OOS (Out of Service) less than 12 months OOS2 - Properly OOS 12+ months OOS3 - Improperly OOS 12+ Months, Viable Owner OOS4 - Improperly OOS 12+ Months, Non-viable Owner	(8) Piping Construction BM - Bare Metal FRP - Fiberglass Reinforced Plastic FPTP - Flexible Plastic Technology Piping
(2) UST Configuration SW - Single Wall SCDW - Secondly Contained Double Walled Tank SCTW - Secondly Contained Triple Walled Tank	(9) Piping Corrosion Protection FLDA - Field Installed Anodes IP - Impressed Current NCWG - No Piping In Contact With Ground
(3) UST Construction BM - Bare Metal CCPS - Coated/Cathodically Protected Steel JS - Jacketed Steel CS - Clad Steel FRP - Fiberglass Reinforced Plastic	(10) Piping Release Detection ELLD - Electronic Line Leak Detector MLLD - Mechanical Line Leak Detector IMT - Int. Monitoring SS - Safe Suction SCVAT - Suction Check Valve at Tank G - Gravity Piping
(4) UST Corrosion Protection FACA - Factory Installed Anodes FLDA - Field Installed Anodes IP - Impressed Current ILNCP - Internally Lined No Cathodic Protection LCP - Lined and Cathodically Protected	(11) Ancillary Equipment SUBP - Submersible Pump in Tank SUCP - Suction Pump at Dispensing Location PIV - Piping Isolation Valve at UST SOLV - Solenoid Valve (e.g., marina piping) FLXUST - Flex Connector at UST FLXDSP - Flex Connector Under Dispenser SV - Shear Valve at Dispenser
(5) UST Release Detection ATG - Automatic Tank Gauging IMTD - Dry Int. Monitoring (D/W Tank)(T/W Tank) IMTW - Wet Int. Monitoring (D/W Tank)(T/W Tank) IMO - Int. Monitoring (Other) MTGL - Manual Tank Gauging (< 550) MTGH - Manual Tank Gauging (551-2000) NR - None Required by Rule AMSIR - Alternative Method (SIR) AMO - Alternative Method (Other, explain)	(12) Spill Containment Manhole (Spill Bucket) SBSW - Single Wall Spill Containment Manhole SBDW - Double Wall Spill Containment Manhole
(6) Piping Configuration SW - Single Wall SC - Secondly Contained	(13) Other Containment Locations TTCT - Tank Top Containment (Tight) TTCNT - Tank Top Containment (Non-Tight) UDCT - Under Dispenser Containment (Tight) UDCNT - Under Dispenser Containment (Non-Tight) PTC - Piping Transition Containment
(7) Piping Style P - Pressure S - Suction G - Gravity	(14) Containment Release Detection SSLOW - Sump Sensor in Lowest Containment SSALL - Sump Sensors in All Containments
	(15) Overfill Prevention FILL - Fill Pipe (drop tube - Shut-off device) VENT - Vent Line (float vent valve - Restrictor Device) ALARM - Alarm
	Other Common Acronyms NR - None Required by Rule NP - None Present Other (explain)