Department of Commerce
Division of Industrial Compliance
John R. Kasich, Governor
Jacqueline T. Williams, Director

Monthly Elevator Firefighters' Operation Service Log

ASME Rule 8.6.10.1 Maintenance of Firefighter's Service. All elevators provided with firefighter's service shall be subjected to monthly Phase I recall a minimum of on-floor operation on Phase II to assure the system is maintained in proper operation order. A written record of findings on the operation shall be maintained and kept on the premises of said operation.

STATE # _____ LOCATION NAME _____

DATE:	PHASE I	PHASE II	CHECKED BY: (Signature)	Passed	Failed

Comments:_____

_____

_____

_____

DIC 4611 (Rev 8/2013)

Bureau of Operations & Maintenance - Elevators
6606 Tussing Road
PO Box 4009
Reynoldsburg, OH 43068-9009 U.S.A.

614 | 644 2223
Fax 614 | 644 2428
TTY/TDD 800 | 750 0750
www.com.ohio.gov

An Equal Opportunity Employer and Service Provider